

Open Bid for new Fire Alarm System at DuPage Township 2/24/2022

- Fire Alarm Service
- Sales Design Equipment Quantity Description Physical Location Already Exists but needs to be brought up to code. Below is a list of equipment required. Building will need additional conduit run. Open for inspection M-F 8:30-4:30 except Federal Holidays.

Bid needs to be submitted prior to March 12th, 2022

1 Facp 1 Loop 64Pt

2 Cl B Nac in Storage Room 2

1 Ground/Surge Prot/Battery

4 Red Ceiling LED A/V 15-115 CD

3 Red Ceiling LED Strobe 15-115

8 Universal Mounting Plate for G4 And GC Series

1 "15,30,75,110 (R) Wall LED Horn/Strobe ""Fire""

1 RLCD-R / RA-ENC1 2 Fixed Data Heat

30 Intelligent Smoke Detector (currently has 11)

32 Standard Detector Base

4 Dbl Action Pull Station

3 Single Input Module for conventional heats in closets

10' 3/4" EMT CONDUIT

Beam Clamp 100 Per Box

Bridle Rings 100 Per Box

14/2 Reg FPL Red (A/V)

16/2 Reg FPL Red (Data